

## Xylem Product Security Advisory

### Xylem AquaView Vulnerability

December 16, 2021

#### Overview

Through proactive security testing, Xylem identified a vulnerability impacting AquaView versions 1.60, 7.x, and 8.x. There is no evidence the vulnerability has been exploited.

#### Vulnerability Details

CVE ID: **CVE-2021-42833**

CVSS v3.0 Base Score 9.3 | **Critical** | CVSS:3.0/AV:L/AC:L/PR:N/UI:N/S:C/C:H/I:H/A:H

A *CWE-798: Use of Hardcoded Credentials* vulnerability exists that could allow an authenticated local attacker to create users, delete users, manipulate users, update system and security levels, or reuse the credentials to further penetrate the system.

#### Affected Products and Versions

- AquaView – Versions 1.60, 7.x, 8.x

#### Mitigation

Please click the link below and follow the instructions to implement the AquaView security upgrade.

1.60

[AquaView 1.60 SecuritySettings.pdf](#)

7.x-8.x

[AquaView 7.x-8.x SecuritySettings.pdf](#)

For assistance with implementing the security settings, please contact Monitoring & Control Technical Support for Flygt products using one of the methods below.

- Create a PAS Case: <https://xylem.my.salesforce.com/console>
- Send an e-mail: [mcaftermarket@xylem.com](mailto:mcaftermarket@xylem.com)
- Call telephone support: +46-8-475 6868

#### References

- [Xylem Product Security Advisories](#)

- CVE-2021-42833: [NIST National Vulnerability Database \(NVD\)](#) and [MITRE CVE® List](#)
- ICSA-21-xxx-xx - [CISA ICS-CERT Advisory](#)

## Contact Information

For any questions related to this Xylem Product Security Advisory, please contact [product.security@xylem.com](mailto:product.security@xylem.com).

For questions related to the AquaView upgrade, please contact +46-8-475 6868.

## Disclaimer

This document is provided on an as is basis and does not imply any kind of guarantee or warranty, including the warranties of merchantability or fitness for a particular use. Use of the information on the document or materials linked from the document is at your own risk. Xylem reserves the right the change or update this document any time.