



**CentriPro**  
a xylem brand

## **SPECIFICATIONS**

CPPANELSPEC

# Customized Control Panel Specification

### **GENERAL**

- Furnish and install CentriPro Customized Control Panel Part No. \_\_\_\_\_. Panel rated for \_\_\_\_\_ hp, \_\_\_\_\_ volts, \_\_\_\_\_ phase power supply. Panel shall be used in installation \_\_\_\_\_ (location).

### **QUALIFICATIONS**

All panel manufacturers must be pre-qualified by the engineer in order to qualify as acceptable manufacturers. Pre-qualification shall be no later than two (2) weeks prior to published bid date for this project. Failure to pre-qualify will be grounds for disqualification after the bid opening date. All decisions of qualification shall reside with the engineer of record at time of bidding.

### **PANEL DESIGN**

Duplex Control panel to operate up to 5 HP, 208 volt, 3 phase pumps, NEMA 1 (indoor) enclosure, pump motor fused disconnects, control circuit breaker, control circuit transformer, motor starters with overloads, H-O-A's and run lights, duplex alternation, 24 VAC float control circuit, high level alarm with bell, dry alarm contacts.

### **LISTINGS**

Panel shall be UL listed. Panels that are not UL listed will not be considered equal.

---

### **Xylem Inc.**

2881 East Bayard Street Ext., Suite A, Seneca Falls, NY 13148

Phone: (866) 325-4210 Fax: (888) 322-5877

[www.xyleminc.com/brands/centripro](http://www.xyleminc.com/brands/centripro)